

बीरबल साहनी पुराविज्ञान संस्थान, लखनऊ
BIRBAL SAHNI INSTITUTE OF PALAEOSCIENCES, LUCKNOW

टेलीग्राम पेलियोबॉटनी

दूरभाष 2740008, 2742983

फैक्स ९१-91-522-2740485, 2740098

बी सा पु सं / III/भंडार एवं क्रय/ N.Khonde / C-1608

53, विश्व विद्यालय मार्ग

लखनऊ - 226007

Date: 10.12.2020

संयोजक वेबसाइट समिति,

बी सा पु सं, लखनऊ

Cold Storage Container (Details at the back)

Subject: -----

Dear Sirs,

This Institute intend to repair / services items mentioned above. Sealed quotations are invited so as to reach this office on or before 5:00 P.M. on 28.12.2020 duly superscribed by "Cold Storage Container" .

While submitting quotation please note that:

1. The material may either of indigenous manufacturer or of foreign make, available from ready stock. Any offer to supply on forward Delivery Basis under suppliers own quota license will also be considered.
2. The price quoted should be F.O.R. Destination.
3. Your rates should include packing, insurance and forwarding charges.
4. The rates of Sales Tax should be clearly indicated wherever chargeable. The tendered should also indicate Central/Sales Tax Registration Number and date in this quotation.
5. Specific mention should be made whether the offer is for supplies available ex-stock. In case the officer is on Forward Delivery basis, firm delivery period must be indicated.
6. The cover should be sealed and superscribed "Quotation for "Cold Storage Container" must be written on envelope. The quotations not complying the procedure will be rejected.
7. Payments will be made by crossed cheque on The Indian Overseas Bank, Lucknow only after receipt and acceptance of supply and installation/ if required satisfactory.
8. The acceptance of the quotation will rest with the Director who does not bind himself to accept the lowest quotation and reserves the right to himself to reject or partially accept any or all the quotation received without assigning any reasons.
9. The quotations are liable to be cancelled if any of the above mentioned conditions are not complied with.
10. The quantity may be increase or decrease at the time of purchase.


14/12/2020

Section Officer
Store & Purchase Section

Specifications for the Cold Storage Unit 40 feet:

Dimensions	L x B x H (40' x 8' x 8' 6")
Material	Exterior: Heavy duty and high structural integrity, Rust free robust Exterior, powder coated Interior: Stainless steel interior with insulated polyurethane (Non-ozone depleting foam insulation) foam of high quality with proper thickness
Manufacturing	Month and year of Manufacturing (ISO 6346 classification and sub classification based on insulation must be mentioned)
Certifications	ISO, Owner marking, data plate and container insurance documents are mandatory
Temperature range	Temperature range; Minus (-) 5 °C to plus (+) 10 °C; with fluctuations of 1 °C or better (must be able to keep inside temperature with 45°C ambient temperature
Display panel	LED display
AC settings should be automatic as well as manual mode	YES
AC function during transport mode	YES/NO (needs to be mentioned)
Schematics	Container and doors - all views mentioning dimensions (inside & outside), Inside volume (To be mentioned).
Strength of Inside walls and floor	Container having non flammable material inside the container. Floor strength should be suitable to handle fork lift/pallet truck with pay load inside the container.
Door	Full Door - with minimal air leakage
Paint	Exterior must be painted; interior should not be painted but should be SS (rust free).
Tare weight and cubic capacity of the container	To be given
Refrigeration	a) Two refrigeration units for alternate cooling (price needs to be quoted for single and double refrigeration units separately). b) Symmetrical bottom-air delivery for better air-distribution
Alarm	a) Advanced two tiered Alarm system b) Mantrap Alarm
Lights inside	220v LED or suitable
Floor	Plain SS or Aluminium (rust proof).
Walls and ceiling	Rustproof Walls and Ceiling
Display unit	Mandatory
Curtain	Strip Curtain
Certification	ISO Standardize; ABS/BV/KRS/CE marking wherever applicable
Warranty	Three year onsite Warranty
Delivery Period	30-45 days
Accessories and Options:	Dehumidification control Optional 460-volt plug (specify)
Diesel Generator	Auto restart, Compatible generator set. All steel frame with integral fuel tank that will allow the unit to run for more than 12 hours.
Transportation and handling	To be transported and installed at BSIP, Lucknow in desired condition by supplier (Transport, installation, loading and unloading is to be done by supplier).
Warranty	3 years AMC (Comprehensive on genset) with quarterly maintenance which includes consumables, technician visit and spare parts etc.
Electrical sockets inside the container	10 number of electric sockets for the power supply with 5A and 15 A sockets of Indian standard
External electric cable	At least 50 meters and must be suitable for India.