

बीरबल साहनी पुरावनस्पती विज्ञान संस्थान, लखनऊ

BIRBAL SAHNI INSTITUTE OF PALAEOBOTONY

ठेलीग्राम : पेलियोबॉटनी
दूरभाष : 2740008, 2740011
फैक्स : 91-522-2740485, 2740098
बी.सा.पु.सं. II/भवन एव निमाण No. II/W&B/BSIP-2015-16/c-1153

53.विश्वविद्यालय मार्ग,
लखनऊ - 226007

Date: 22-12-2015

Convener Website Commttee

Subject: -Quotation for 125 KVA Servo based main line voltage stabilizer.

Dear Sir,

We are interested in purchase of the articles mentioned above, Please send your quotation in sealed covers so as to reach this office of or before 30.12.2015 While submitting quotation please note that : -

1. We are interested in the material from manufacturer.
2. The price quoted should be F.O.R. Destination.
3. Your rates should include packing, insurance and forwarding charges.
4. The rates of Sales Tax/VAT/Service Tax should be clearly indicated wherever chargeable. The Quotation should also indicate Central/Sales Tax Registration Number/PAN and date in this quotation.
5. Specific mention should be made whether the offer is for supplies available ex-stock. In case the officer is on Forward Delivery basis, firm delivery period must be indicated.
6. The cover should be sealed and subscribed **"Quotation for above must be written on envelope.** Date of opening Next day. The quotations not complying the procedure will be rejected.
7. Payments will be made by crossed cheque on The Indian Overseas Bank, Lucknow only after receipt of the material in good condition.
8. The acceptance of the quotation will rest with the Director who dose not bind himself to accept the lowest quotation and reserves the right to himself to reject or partially accept any or all the quotation received without assigning any reasons.
9. The quotations are liable to be cancelled if any of the above mentioned conditions are not compiled with.

Yours Sincerely,



(R.S. Singh)

Scientist. 'G' with additional duty of Registrar

Specification of Stabilizer are attached herewith

Specifications of voltage stabilizer:

Load: 125 KVA three phase and Neutral for all type of loads

For input voltage range: 320V -460 V

Output Voltage: 400 ± 1

Max load: 41.5 KVA per phase

Maximum current: 138 Amp per phase

Correction speed: ~ 10 V/sec

Cooling type: oil cooled

Working temperature range: 5-50°C

Service and installation: Vendor must ensure its delivery, full service and installation on-site i.e. 53 University Road BSIP campus.

Minimum warranty: One year or more

Compatibility: Vendor must ensure compatibility of stabilizer with institute power supply and it must be installed appropriately for uninterrupted supply of power for the laboratory.

Display digitally control panel depicting input and out voltage

Provision for Surge protection

Provision for cut off facility

Protection from phase reversal if any

AMC after warranty period can also be quoted.