

बीरबल साहनी पुरावनस्पतिविज्ञान संस्थान, लखनऊ
BIRBAL SAHNI INSTITUTE OF PALAEOBOTANY, LUCKNOW

टेलीग्राम पेलियोबॉटनी

दूरभाष 2740008,2740011

फैक्स ९१-91-522-2740485,2740098

बी सा पु सं /III/भंडार एवं क्रय/८-1042

53, विश्व विद्यालय मार्ग

लखनऊ - 226007

Date: 01.12.2015

Convener, Website Committee
BSIP, Lucknow

Servo Based Voltage Stabilizer (Detailed specification at the back)

Subject: -----


Dear Sirs,

This Institute intend to purchase item mentioned above. Sealed quotations are invited so as to reach this office on or before 5:00 P.M. on 15.12.2015 duly superscribed by **"Servo Based Voltage Stabilizer** due to open in presence of vendors at a later date to be notified.

While submitting quotation please note that:

1. The material may either of indigenous manufacturer or of foreign make, available from ready stock. Any offer to supply on forward Delivery Basis under suppliers own quota license will also be considered.
2. The price quoted should be F.O.R. Destination.
3. Your rates should include packing, insurance and forwarding charges.
4. The rates of Sales Tax should be clearly indicated wherever chargeable. The tendered should also indicate Central/Sales Tax Registration Number and date in this quotation.
5. Specific mention should be made whether the offer is for supplies available ex-stock. In case the officer is on Forward Delivery basis, firm delivery period must be indicated.
6. The cover should be sealed and superscribed "Quotation for **"Servo Based Voltage Stabilizer"** must be written on envelope. The quotations not complying the procedure will be rejected.
7. Payments will be made by crossed cheque on The Indian Overseas Bank, Lucknow only after receipt and acceptance of supply and installation/ if required satisfactory.
8. The acceptance of the quotation will rest with the Director who does not bind himself to accept the lowest quotation and reserves the right to himself to reject or partially accept any or all the quotation received without assigning any reasons.
9. The quotations are liable to be cancelled if any of the above mentioned conditions are not complied with.

Yours sincerely,



(Dr.R.S.Singh)
Scientist 'G'

with Additional duties of Registrar

Dr. P. Kashyap

Specifications of voltage stabilizer:

Load: 20 KVA three phase

For voltage range: 320V -460 V

Output Voltage: 400 ± 1

Max load: 6.5 KVA per phase

Maximum current: 22 Amp per phase

Cooling type: oil cooled

Working temperature range: 5-50°C

Service and installation: Vendor must ensure its delivery, full service and installation on-site i.e. 53 University Road BSIP campus.

Minimum warranty: One year or more

Compatibility: Vendor must ensure compatibility of stabilizer with institute power supply and it must be installed between main line and UPS of CF-EA-GB-IRMS.

Display digitally control panel depicting input and out voltage

Provision for Surge protection

Provision for cut off facility

Protection from phase reversal if any

AMC after warranty period can also be quoted.