

बीरबल साहनी पुराविज्ञान संस्थान, लखनऊ
BIRBAL SAHNI INSTITUTE OF PALAEOSCIENCES, LUCKNOW

टेलीग्राम पेलियोबॉटनी

53, विश्व विद्यालय मार्ग

दूरभाष 2740008,2742983

लखनऊ - 226007

फैक्स ९१-91-522-2740485,2740098

बी सा पु सं /III/भंडार एवं क्रय/C-659

Date: 16.08.2017

संयोजक वेबसाइट समिति,

बी सा पु सं, लखनऊ

20 KVA online UPS (specification at the back)

Subject: -----

Dear Sirs,

This Institute intend to purchase item mentioned above. Sealed quotations are invited so as to reach this office on or before 5:00 P.M. on 01.09.2017 duly superscribed by "20 KVA UPS " .

While submitting quotation please note that:

1. The material may either of indigenous manufacturer or of foreign make, available from ready stock. Any offer to supply on forward Delivery Basis under suppliers own quota license will also be considered.
2. The price quoted should be F.O.R. Destination.
3. Your rates should include packing, insurance and forwarding charges.
4. The rates of Sales Tax should be clearly indicated wherever chargeable. The tendered should also indicate Central/Sales Tax Registration Number and date in this quotation.
5. Specific mention should be made whether the offer is for supplies available ex-stock. In case the officer is on Forward Delivery basis, firm delivery period must be indicated.
6. The cover should be sealed and superscribed "Quotation for "20 KVA UPS " must be written on envelope. The quotations not complying the procedure will be rejected.
7. Payments will be made by crossed cheque on The Indian Overseas Bank, Lucknow only after receipt and acceptance of supply and installation/ if required satisfactory.
8. The acceptance of the quotation will rest with the Director who does not bind himself to accept the lowest quotation and reserves the right to himself to reject or partially accept any or all the quotation received without assigning any reasons.
9. The quotations are liable to be cancelled if any of the above mentioned conditions are not complied with.
10. The quantity may be increase or decrease at the time of purchase.


(Sanjay Kumar)
Registrar

Technical Specifications of UPS

Suitable for Three phase AC input and output, Floor mounted Type.

20 KVA power rating

45-60 min backup at full load

Should have provision for Static Bypass

Should have provision for correcting power phase alternating if any

Should have provision to get changed with mains supply with voltage varying from 150-280 volts with nominal voltage input 230 ± 1 , Current frequency 50-60 Hz.

Digital display with clear provision of reset

Button, Providing voltage 230 ± 10 volt supply (50-60 Hz) Sine wave output

Having standard branded batteries with minimum 2 year warranty (leak-proof; maintenance free)

Housing racks for batteries would be provided by the supplier

Possibly having surge protection

Operable at temp between $5-40^{\circ}\text{C}$; RH 10-90%

Overall warranty minimum One year for system and two year for batteries

attached